



AB 054

Division of Glass and Building Materials in Krakow

31-983 Krakow, Cementowa 8 Str.

tel.: +48 12 683 79 00

fax: +48 12 683 79 01

www.icimb.pl

info_krakow@icimb.pl

Department of Gypsum and Building Chemistry

tel.: +48 12 683 79 77

m.niziurska@icimb.pl

Sponsor: *ALPHA Construction AG, Bahnhofstrasse 21, 6301 Zug, Switzerland*

Sample: *INSULATING PAINT PSC - 250T-HP*

TEST CERTIFICATE

1) SBI

PN-EN ISO 13283:1010

FIGRA_{0,2 MJ}

45,27 W/s

FIGRA_{0,4 MJ}

12,66 W/s

LFS< till edge

Yes

THR_{600s}

1,08 MJ

SMOGRA

0,00 m²/s²

TSP_{600s}

22,90 m²

Burner substantially
disturbed/choked

No

F_s ≤ 150 mm during 60 s

2) Ignitability

PN-EN ISO 11925-2:2010

3) Classification using data from
reaction to fire tests

PN-EN 13501-1+A1:2010

B-s1,d0



[Signature]

Verification

Z-ca Kierownika Zakładu
Gipsu i Chemii Budowlanej

[Signature]
mgr inż. Michał Wiczorek

Signature of entitled person